



## Audit Finance

### Shawnee County PURCHASING DIVISION

MICHELE HANSHAW  
Audit Finance Department  
Purchasing Specialist  
200 SE 7<sup>th</sup> St., Room 201

#### ADDENDUM #1

Addendum Issue Date: 01/09/23

Lake Shawnee Shelter #3 – Mandatory Pre-bid Q&A – Bid #: 067-22 –01/05/2023

- In regards to the Minimal Requirements section, E-c; It has been determined that we would like to remove the vertical pickets and instead, continue with the current horizontal “backrest” board all the way around. Horizontal board(s) should continue around the deck rails/railings including the ramp rails.
- In regards to the Minimal Requirements section, E-d; Remove the word “angled”. The current backrests are vertical, not angled so new construction should maintain the current configuration.

Q. Is the addendum dated 11/29/022 still in effect?

A. The addendum from the first meeting was added to the second RFQ.

Q. Under Minimal Requirements E.- f. Fascia front of deck to be covered in one inch material. Do you want that from the top of the deck to the ground or just on the rim boards?

A. From the top of the deck to the ground.

Q. For the ADA ramps, Will the county be moving any landscaping material and the grill if it needs to be removed?

A. Any landscaping material that may interfere with the deck build should be moved or removed by the winning contractor. It is not anticipated that the grill would need to be moved since it’s location is far enough away from the deck that it should not pose a problem with the deck build.

You will be required to acknowledge this addendum in the bid portal.

All other terms and conditions of the bid remain the same.

Michele Hanshaw

Purchasing Specialist