

# SHAWNEE COUNTY PURCHASING DIVISION

707 SE Quincy, Suite 319 Topeka, Kansas 66603 Ph. 785.251.4307 Email: AuditFinance@snco.us Website: www.snco.us

# REQUEST 003-23 – FIRE PROOFING AND CEILING REPAIRS JDC ADDENDUM #1 ADDENDUM ISSUE DATE: 1/26/2023

# Questions and Answers from the Pre-Bid meeting held on 1/25/2023

# 1. Do we have the measurements/blueprints of the area?

a. No, Contractors are responsible to field verify all measurements.

### 2. What is the hourly rating for the Fire Proofing that is currently being used?

a. The current fire rating per original blueprints is 2 hours. The scope of work indicates that the contractor will reinstall fireproofing to meet current building codes and standards.

#### 3. What size lift can they use?

a. They can use whatever will fit through a standard interior door

#### 4. What is the thickness of the current ceiling tile?

a. The ceiling tile is 1/2" thick

#### 5. What power source will be available?

a. We have 110 volts through the electrical outlets, contractor will be responsible for supplying anything else

# 6. What type of tool inventory?

a. There will be a master tool list/inventory for an on-site "gang box" for all contractors and subcontractors, the tools will be monitored and maintained on-site for the duration of the contractor/subcontractor work

# 7. How many living units can be worked on at one time?

Due to our population, only one unit can be worked on at a time. Once all work is completed on the unit, the residents from another unit will be moved to it allowing the vacated unit to be worked on.
Example: Start on "Unit A", complete "A". Residents from "Unit B" will move to "A" that day or the next day (depending on completion time) and work will begin on "B".

# 8. What LED light panel do you currently use?

a. The model number of the current LED light panel we use is LITH - CPX2X4ALO8SWW7M2 35/40/50K LUMEN SELECT

### 9. Is this a SAM.gov project?

a. No, no special requirements due to federal funding

#### 10. Will there be background checks for workers?

a. Yes, to include offender registry. A waiver form will be provided to the contractor that each employee will need to complete, sign and have notarized. Employee will need to provide a copy of a US government picture ID.

#### Question and Answer from Bid Portal on 1/26/2023

#### 1. Does the existing fire proofing contain asbestos?

a. No, the JDC was built in the late 90's after asbestos stopped being used in building materials.